

The magic of heat reuse- Waste Heat recovery project


- VIS FAC Department manager : Alex Wang
- VIS FAC manager : Danny Chen, Jacky Liu, Eric Lai, W.J. Leu , Tiger Wang, S.F. Chen, David Kao
- BenQ ESCO : Jason Lin, Shou C Chen, David Chiu, Anderson Liu, Leo Huang, Dempsey Tseng.

Time: Jun 2018- Sep 2019

Benefit: NT\$20,588,212



Guideline



1. Introduction

Hot Ultra Pure Water system(HOT UPW)


Make-Up Air Unit (MAU) system




VIS steam enter point



Power Plant of Nanya Plastic Corporation



Nanya PCB 5 steam enter point






Dormitory steam enter point

1. Introduction


Steam cost: 30,845,320 NTD/year

Increase of steam cost: **44%** (2016-2018)




2.Relevant System

- **MAU system**
 1. For **MAU** system, **steam** is important for the temperature & humidity regulation.
 2. Steam usage for MAU : 20,890 ton/year → \$ 20,221,520/year.
- **HOT UPW system**
 1. For **HOT UPW** water system, **steam price** accounts for most of the running cost.
 2. Steam usage for HOT UPW : 10,974 ton/year → \$ 10,622,832/year.




temperature & humidity regulation.




2.Relevant System

- CDA system

1. In VIS, there are 6 air compressor(N5900 for UIGC).
2. For **CDA** system, average 125,000 m³ /day of air producing and 18,000kwh of power consumption per day.



2.Relevant System



3. Team member

Captain FAC

Alex Wang(VIS)

- Schedule management
- Task assignment

Danny Chen (VIS)
Jacky Liu (VIS)
Eric Lai (VIS)
W.J. Leu (VIS)
Jason Lin (BenQ ESCO)

Do it

BenQ ESCO

FAC
W.G.C Section


FAC
M.E Section

IE




4. Waste Heat Recovery Project

- Heat Pump



- Waste Heat recovery




Item	principle	Advantage
Heat pump	Base on second law of thermodynamics, which transfer the energy from low-temperature to high-temperature	Heat & Cold energy generate simultaneously.
Waste Heat recovery	Heat Exchange by changing the loop of cooling water.	No extra power consumption




4. Waste Heat Recovery Project

- Waste Heat recovery(Normal)




- Waste Heat recovery(BenQ ESCO)



Item	method	Advantage
Waste Heat recovery(normal)	Heat recovery only by the end of output(compress air).	No need for compressor revising.
Waste Heat recovery(BenQ ESCO)	Heat recovery from both cooling water and compress air .	Maximize the amount of recover ratio.




4. Waste Heat Recovery Project






No.	Power	Type	Production
A-101	300HP	Screw	70°C
A-102	300HP	Screw	70°C
A-103	500HP	Centrifugal	35°C, 95°C
A-104	350HP	Screw	70°C
A-105	500HP	Centrifugal	35°C, 95°C
N-5900	2250HP	Centrifugal	35°C



4. Waste Heat Recovery Project



4. Waste Heat Recovery Project





As is Amount of steam for input water 52°C
 $20\text{CMH} \times 1000\text{kg} \times (80^\circ\text{C} - 52^\circ\text{C}) / 860 = 1.035\text{ton/hr}$
 To be Amount of steam for input water 64°C
 $15\text{CMH} \times 1000\text{kg} \times (80^\circ\text{C} - 64^\circ\text{C}) / 860 = 0.443\text{kg/hr}$
 $1.035 - 0.443 = 0.591\text{ton/hr}$
 $0.591\text{ton/hr} \times 24\text{hr} \times 365\text{day} = 5179.5\text{ton/year}$
 Benefit = **5,013,723** NTD/year




4. Waste Heat Recovery Project

35°C from CDA




VIS-3 2019 Benefit




5. Benefit

Steam hourly usage during the process (including MAU and HOT UPW)



65% down



	Jul	Aug	Sep	Oct
2017	2,117	2,132	2,023	2,144
2019	737	731	711	722
Steam saving	65%	66%	65%	66%



5. Benefit

Direct benefit (Steam saving)

Item	Action for steam saving	Steam saving	Benefit(year)
1	35° C source from CDA system(MAU)	1,988 kg/hr	\$10,685,955
2	80° C source from UF concentration(HOT DI)	591kg/hr	\$5,013,723
3	35° C source from CDA system(HOT DI)		
4	70° C source from CDA system(HOT DI)		
5	95° C source from CDA system(HOT DI)		
sum			\$15,699,678

Indirect benefit (Power saving)

Item	Power saving(kWh)	Benefit(year)
VIS-3 Chilled water	1,562,711	\$3,328,575
VIS-3 Cooling water pump	641,820	\$1,367,077
VIS-3 Dryer	90,555	\$192,882
sum		\$4,888,534

Total benefit:

NT \$ 20,588,212





